

CERTIFICATE

of constancy of performance

1922 - CPR - 0330

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fixed firefighting systems - Components for gas extinguishing systems - high and low pressure selector values and their actuators

(The relevant types and are characteristics described in Annex I which is an inseparable part of this certificate)

placed on the market under the name or trade mark of

OML S.r.l.

Via M. Natalucci 6, 60131 ANCONA, Italy

and produced in the manufacturing plant of

OML S.r.l.

Via Sant'Andrea, 38, 20010 BAREGGIO, Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12094-5:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 20.06.2014 and will remain valid until 19.06.2020 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Issued:
Burgas, 19 June 2019

Embossed stamp of "Dedal - A&C" Ltd.

Manager:



arch. Galina Vasileva



ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922-CPR-0330/ 19.06.2019

MANUFACTURER: OML S.r.l.


Trade Mark	Code	Diameter	Internal Diameter	Pressure	Material	Allowed Gas	Mounting Position
OML	10P001	1"	25 mm	140 bar	Bronze	HFC, High-Pressure CO ₂	Wall
OML	10P003	1"1/2	35 mm	140 bar	Bronze	HFC, High-Pressure CO ₂	Wall
OML	10P005	2"	50 mm	140 bar	Bronze	HFC, High-Pressure CO ₂	Wall
OML	10P007	2"1/2	65 mm	140 bar	Bronze	HFC, High-Pressure CO ₂	Wall
OML	10P020	2"	50 mm	235 bar	Bronze/Aluminum	HFC, High-Pressure CO ₂ and Inert Gases	Wall
OML	10P021	2"1/2	65 mm	235 bar	Bronze/Aluminum	HFC, High-Pressure CO ₂ and Inert Gases	Wall
OML	11P001	1"	25 mm	366 bar	Stainless Steel	HFC, High-Pressure CO ₂ and Inert Gases	Wall
OML	11P004	1"1/2	35 mm	366 bar	Stainless Steel	HFC, High-Pressure CO ₂ and Inert Gases	Wall
OML	11P007	2"	50 mm	366 bar	Stainless Steel	HFC, High-Pressure CO ₂ and Inert Gases	Wall
OML	11P010	2"1/2	65 mm	366 bar	Stainless Steel	HFC, High-Pressure CO ₂ and Inert Gases	Wall

This certificate was first issued on 20.06.2014 and will remain valid until 19.06.2020 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Issued:
Burgas, 19 June 2019

Embossed stamp of "Dedal - A&C" Ltd.



Manager:



arch. Galina Vasileva

