

CERTIFICATE

of constancy of performance

1922 - CPR - 0331

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fixed firefighting systems - Components for gas extinguishing systems - non-electrical automatic control and delay devices

(The relevant types and are characteristics described in Annex I which is an inseparable part of this certificate)

placed on the market under the name or trade mark of

OML S.r.l.

Via M. Natalucci 6, 60131 ANCONA, Italy

and produced in the manufacturing plant of

OML S.r.l.

Via Sant'Andrea, 38, 20010 BAREGGIO, Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12094-2:2003

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 24.06.2014 and will remain valid until 19.06.2020 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Issued:
Burgas, 19 June 2019

Embossed stamp of "Dedal - A&C" Ltd.



Manager:




arch. Galina Vasileva

**ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE
1922-CPR-0331/ 19.06.2019****MANUFACTURER: OML S.r.l.**

Product	Trade Mark	Code	Diameter	Pressure	Allowed Gas
Delaying valve	OML	04P048	3/4	140 bar	High-Pressure CO2
Delaying valve without lever	OML	04P050	3/4	140 bar	High-Pressure CO2
Adjustable delaying valve	OML	04P051	3/4	140 bar	High-Pressure CO2
Adjustable delaying valve without lever	OML	04P052	3/4	140 bar	High-Pressure CO2

This certificate was first issued on 24.06.2014 and will remain valid until 19.06.2020 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.

Issued:
Burgas, 19 June 2019**Manager:**

arch. Galina Vasileva