

CERTIFICATE

of constancy of performance

1922 - CPR - 0687

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fixed firefighting systems. Components for gas extinguishing systems. Nozzles for CO₂ systems

(With tested characteristics described in Annex I which is an inseparable part of this certificate)

placed on the market under the name or trade mark of

OML S.r.l.

Via Achille Grandi, 13/a- 60131, Ancona (AN), Italy

and produced in the manufacturing plant

OML S.r.l.

Via Sant'Andrea, 38, 20010 Bareggio (Milan-Italy)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12094-7:2000, EN 12094-7:2000/A1:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 05.07.2016 and will remain valid until 19.06.2024 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Manager: 

Issued:
Burgas, 19 June 2020

dipl. eng. Anna Vasileva

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922-CPR-0687/ 19.06.2020

Nozzle	Number of holes	Bore diameter (mm)	Cross section (mm ²)
N03	2	1	1.57
N04	4	1	3.14
N05	2	1.5	3.53
N06	2	2	6.28
N07	4	1.5	7.07
N08	2	2.5	9.81
N09	4	2	12.56
N10	2	3	14.13
N11	2	3.5	19.23
N12	4	2.5	19.63
N13	2	4	25.12
N14	4	3	28.26
N15	2	4.5	31.79
N16	4	3.5	38.47
N17	2	5	39.25
N18	2	5.5	47.49
N19	4	4	50.24
N20	2	6	56.52
N21	4	4.5	63.59
N22	2	6.5	66.33
N23	2	7	76.93
N24	4	5	78.50
N25	2	7.5	88.31
N26	4	5.5	94.99
N27	2	8	100.48
N28	4	6	113.04
N29	4	6.5	132.67
N30	4	7	153.86
N31	4	7.5	176.63
N32	4	8	200.96

This certificate was first issued on 05.07.2016 and will remain valid until 19.06.2024 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Manager:

Anna Vasileva

Issued:
Burgas, 19 June 2020

dipl. eng. Anna Vasileva