

# CERTIFICATE

## of constancy of performance

### 1922 - CPR - 0331

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

#### **Fixed firefighting systems - Components for gas extinguishing systems - non-electrical automatic control and delay devices**

(The relevant types and are characteristics described in Annex I which is an inseparable part of this certificate)

placed on the market under the name or trade mark of

**OML S.r.l.**

**Via M. Natalucci 6, 60131 ANCONA, Italy**

and produced in the manufacturing plant of

**OML S.r.l.**

**Via Sant'Andrea, 38, 20010 BAREGGIO, Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

#### **EN 12094-2:2003**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 24.06.2014 and will remain valid until 19.06.2024 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address [www.dedal-bg.net](http://www.dedal-bg.net).



Attestation & Certification

*Anna Vasileva*

Manager:

dipl. eng. Anna Vasileva

Issued:  
Burgas, 19 June 2020

**ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE  
1922-CPR-0331/ 19.06.2020****MANUFACTURER: OML S.r.l.**

Product	Trade Mark	Code	Diameter	Pressure	Allowed Gas
Delaying valve	OML	04P048	3/4	140 bar	High-Pressure CO2
Delaying valve without lever	OML	04P050	3/4	140 bar	High-Pressure CO2
Adjustable delaying valve	OML	04P051	3/4	140 bar	High-Pressure CO2
Adjustable delaying valve without lever	OML	04P052	3/4	140 bar	High-Pressure CO2

This certificate was first issued on 24.06.2014 and will remain valid until 19.06.2024 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address [www.dedal-bg.net](http://www.dedal-bg.net).

**Manager:**  
*Anna Vasileva*Issued:  
Burgas, 19 June 2020

dipl. eng. Anna Vasileva